



EC Declaration of Conformity - Xtralis VESDA VLC

The undersigned, representing

Xtralis Pty Ltd (ACN 008 009 514)
4 North Drive, Virginia Park
236-262 East Boundary Road
Bentleigh East
Victoria 3165
Australia

hereby declare that the following apparatus

Aspirating Smoke Detector for fire detection and fire alarm systems for buildings.

Model Designation

Xtralis VESDA VLC Range of products:

- VLC-500
- VLC-505
- VLC-50000-NF
- VLC-50500-NF
- VLC-70000-NF or 801519.F0
- VLC-400
- VLC-800

Optional ancillary equipment (also approved in a 19" sub rack)

- VRT-J00 Remote VLC display with 7 relays
- VRT-500 Remote VLC relay unit with 7 relays
- VRT-K00 Remote VLC display with no relays

are in conformity with the provisions of the following EC Directive(s)

- EMC Directive 2004/108/EC

Note: the products are also in conformity of the Construction Products Regulations (CPR) for which a separate Declaration of Performance (DoP) is provided and may be obtained by emailing DoP-VESDA@xtralis.com

and that the following standards have been applied

- EN 50130-4: 2011 Alarm systems – Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
- EN 61000-6-3/A1: 2011 Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments



Empowered Signatory of Company

I the undersigned, hereby declare on behalf of Xtralis that the products listed above comply with the requirements of the standards listed above which gives presumption of conformity with the essential requirements of the directives listed above.

Name: Samir Samhour

Position: Chief Executive Officer

Signature:

A handwritten signature in black ink, appearing to read 'S. Samhour'.

Date: October 10, 2014