

# BRE Global

**Notified Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance

### 0832-CPR-F1132

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### 801711.10 Addressable Single Channel Aspirating Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Esser by Honeywell  
Novar GmbH  
Dieselstrasse 2  
41469 Neuss  
Germany

and produced in the manufacturing plant(s):

Pittway Tecnologica Srl  
Via Caboto 19/3  
34147 Trieste  
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-17:2005 - Short circuit isolators  
EN 54-18:2005 - Input/output devices  
EN 54-20:2006 - Aspirating smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 28 September 2015 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 28 September 2015

Date of Issue: 26 September 2018

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

**BRE Global Limited**

Bucknalls Lane,  
Garston, Watford,  
Hertfordshire, UK,  
WD25 9XX

**Notified Body No. 0832**

Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-CPR-F1132****801711.10 Addressable Single Channel Aspirating Detector****Accessories:**

F-INF-25 In line filter

**Notes:**

1. Incorporating an Esser Alarm transponder 808623
2. For compliance with Clause 5.10 of EN54-20: 2006, the detector must be supplied by a power supply complying with EN54-4.
3. The devices are only approved at the following levels:
  - Alarm Level 1 meets class A, B and C
  - Alarm Levels 2-3 meets class B and C
  - Alarm Levels 4-5 meet class C only

With Filter, part number F-INF-25

- Alarm Levels 1-2 meet class B and C
  - Alarm Level 3 meets class C only
4. The class of any pipe / hole configuration and detector sensitivity must be determined using PipelQ software (version 2.9 or higher), with the EN54 option selected.

A handwritten signature in black ink, appearing to read 'P. Halligan'.

P Halligan, Certification Manager,  
On behalf of BRE Global Limited

Date of First Issue: 28 September 2015

Date of Issue: 26 September 2018

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).