



## EC Declaration of Conformity - Xtralis VESDA VLI

The undersigned, representing

Xtralis Pty Ltd (ACN 008 009 514)  
4 North Drive, Virginia Park  
236-262 East Boundary Road  
Bentleigh East  
Victoria 3165  
Australia

hereby declare that the following apparatus

Aspirating Smoke Detector for fire detection and fire alarm systems for buildings.

### Model Designation

Xtralis VESDA VLI Range of products:

- VLI-880 VESDA VLI with relays and Ethernet only
- VLI-88000-NF (French variant of above)
- VLI-885 VESDA VLI with VESDAnet
- VLI-88500-NF (French variant of above)

Optional ancillary equipment (also approved in a 19" sub rack)

- VRT-500 Remote Relay Unit with 7 Relays
- VRT-Q00 Remote VLI Display with 7 Relays
- VRT-T00 Remote VLI Display with no Relays

are in conformity with the provisions of the following EC Directive(s)

- EMC Directive 2004/108/EC

Note: the products are also in conformity of the Construction Products Regulations (CPR) for which a separate Declaration of Performance (DoP) is provided and may be obtained by emailing DoP-VESDA@xtralis.com

and that the following standards have been applied

- EN 50130-4: 2011 Alarm systems – Part 4:  
Electromagnetic compatibility - Product family  
standard: Immunity requirements for  
components of fire, intruder, hold up, CCTV,  
access control and social alarm systems
- EN 61000-6-3/A1: 2011 Electromagnetic compatibility (EMC) - Part 6-3:  
Generic standards - Emission standard for  
residential, commercial and light-industrial  
environments



---

**Empowered Signatory of Company**

I the undersigned, hereby declare on behalf of Xtralis that the products listed above comply with the requirements of the standards listed above which gives presumption of conformity with the essential requirements of the directives listed above.

Name: Samir Samhouri

Position: Chief Executive Officer

Signature:

Date: June 12, 2014